

GENERAL	1	Job No		24852				
	2	Project Name		PCAPP				
	3	Tag number		EE-J07 -XT 3012---				
	4	Service		North side of ERB				
	5	Room number	P&ID	n/a		N/A		
	6	Hazardous area class	Ignition temp ident number	Non-classified				
	7	Agent Contamination Category		E				
	8	Ambient temperature Min	Max	-20		104		
	9	Camera/Positioner mounts	Design Life	Yes		5 Year		
	10	Cable harness	Connection box	yes		yes		
LOCATION	11	Drawing	Mounting detail	24582-RD-JD-J07-J0022		*		
	12	Mechanical interface	Mechanical interface ID no	*		*		
	13	Electrical interface	Electrical interface ID no	*				
	14	Elevation	Column number	Gridline	Facing	*		
ENVIRONMENT CONDITIONS	15	DESIGN CONDITIONS		Units	Minimum	Maximum		
	16	Design pressure		inHg-a	28	32		
	17	Design temperature		°F	-20	104		
	18	Relative humidity		%	0	100		
	19	Illumination level		LUX	2	Sun Light		
	20	Wind Velocity		MPH	0	90		
	21	Chemical Contaminants		N/A				
	22	Lighting type	Vibration	High Pressure Sodium Vapor		NA		
	HOUSING	23	Housing type	Outdoor				
		24	Construction style	*				
25		Purge connections	*					
26		Enclosure protection	NEMA 4x					
27		Mounting type	Roof					
28		Housing material	aluminium					
29		Composite cable connect.	*					
30		Purge/Cooling connect.	N/A					
31		Window washer/wiper	No					
32		Cooling Media/Rate	N/A					
33		Heater power	Load	120vac	10w			
34		Blower power	Load	N/A	N/A			
35		Thermostat	yes					
36		Sun shield	Yes					
OPTICS	37	View format/type	zoom					
	38	Imager type	Size	CCD	1/2"			
	39	Lens optical format	1/2 "					
	40	Aperature control	auto w/remote override					
	41	Aperature range (f-stop)	*					
	42	Shutter speed control	Automatic					
	43	Lens mounting type	*					
	44	Focus control	auto w/remote override					
	45	Focal length wide	Narrow	*	*			
	46	Field Range	Depth	*				
	47	Field Height	Width	*				
	48	View angle	* deg *					
	49	FOV wide angle	Narrow	* deg*	deg*			
	50	Optical filters	*					
	51	Zoom control	remote					
	52	Zoom magnification	0.6X to 10X					
	53	Lens window material	*					
	AUXILIARY LIGHTING	54	Lighting type	*				
55		Lighting control	*					
56		Nominal Power	Load	*	*			
* Seller to complete or verify information. See notes								
91	Component type		Manufacturer		Model number			
92	Camera & Positioner		*		*			
93	Lens		*		*			
94	Housing		*		*			
				INSTRUMENT DATA SHEET			Bechtel Pueblo Team	
				CCTV Camera				
A	By	Chk	Appr	Date	Issued for Use	Quality Level: Non-Q	Sheet 1 of 2	
No	By	Chk	Appr	Date	Description	Code: 37021 DS No:24852-RD-JDD-J07-J0012	Rev: A	

Tag number : EE-J07 -XT 3012---

- 1) This camera does not perform security Functions
- 2) Heater and Defroster with thermostat shall be provided
- 3) Lightning protection shall be provided
- 4) Surge protection shall be provided on any power lines, video lines, sync lines, and control signal lines.

				INSTRUMENT SPECIFICATION  CCTV Camera		<b>Bechtel Pueblo Team</b>	
A	GC	5/2/06	Issued for Use			Sheet 2	of 2
No.	By	Date	Revision	Code:37021	Dwg. No.: 24852-RD-JDD-J07-J0012	Rev.: A	